

ERRATA

FOR THE LOCAL AMENDMENTS TO THE 2007 CALIFORNIA FIRE CODE

(California Code of Regulations, Title 24, Part 9)

October 16, 2007

(Note: Items shown underlined denote the errata item that was revised).

SDMC Chapter 5 Article 5 Division 6

- **§55.0603**

Chapter 6, Section 603.3.2.4 (Revise Code references)

603.3.2.4 Installation. Tanks and piping systems shall be installed and separated from other uses in accordance with NFPA 37 ~~IMC Section 915~~ and CMC ~~IMC~~ Chapter 13, as applicable.

Reason: The IMC was not adopted by the State of California. There is no correlating section in the California Mechanical Code (CMC) for IMC Section 915 which addresses the installation of liquid-fueled stationary internal combustion engines and gas turbines. However, IMC Section 915 does reference NFPA 37. NFPA 37 (2002 Edition) “*Installation and Use of Stationary Combustion Engines and Gas Turbines*” is an adopted referenced standard in CFC Chapter 45. Finally, reference to IMC Chapter 13 was changed to CMC Chapter 13. CMC Chapter 13 addresses fuel gas piping and therefore is applicable.

SDMC Chapter 5 Article 5 Division 6

- **§55.0603**

Chapter 6, Section 603.4.2.3.4 (Delete entire section)

~~**603.4.2.3.4 Indoor storage prohibited.** Gas containers shall not be stored inside as required by the *International Fuel Gas California Mechanical Code*.~~

Reason: This section was inadvertently transferred from an earlier draft and was not intended to be in the final draft document. Additionally, after consulting with the proponent of this code change, this section was not part of the proponent’s original submittal even though it appeared in the monograph. Finally, indoor storage of LP gas is permitted and is subject to regulation found elsewhere in the CFC.